

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1574:167 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ, 07004-1561
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

DESIGN: Model ADT **BCI**³⁻³ Building Communicator Interface unit. Unit is intended for use with listee's separately listed model Multi-Net Manager proprietary and central station receiving unit to interface between fire alarm, burglar alarm, access and energy management control equipment and a proprietary control unit through the public telephone switching network. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120/240 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as building communication interface unit for use with listee's separately listed compatible fire alarm control units and model Multi-Net Manager (CSFM Listing No. 7300-1574:169).

NOTE: Formerly 7300-0085:183

XLF: 7300-1525:101

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 23, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager